

Jal Jeevan Mission Har Ghar Jal



DLL Goalpara

o/o The Executive Engineer, PHE Goalpara Div, Goalpara, Near DC office, Pin: 783121 9613813883

Test report

Sample ID

U50021L80254638963

User Information

Name of the Principal:- Dr Subhash Barman

Designation

Department

Public Health Engineering Department

9864301782

Email

dipaksarmedh@gmail.com

Source Information

Location of the Source: - Goalpara College

Village:

GOBINDAPUR (CT)

Gram Panchayat:

BALIJANA

Block

District:

State:

ASSAM

Address:

Goalpara College, Goalpara Town, Ward No.-6, Goalp 783101

Remarks:

4112, Goalpara College (1)

Latitude

Longitude:

Date time of sample collection

Date time of sample received in the lab

Date time of report generation

14.03.22 | 12:10 PM

14.03.22 | 01:30 PM

16.03.22 | 12:39 PM

16.03.22 | 01:05 PM

Test results

Report no

4638963

s. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value Remarks
1	Turbidity*	NTU	1	5	0.00
2	рН*	NA	6.5-8.5	No Relaxation	7.43
3	Total Alkalinity (as Calcium Carbonate)*	Milligram/liter	200	600	48
4	Chloride (as CI)*	Milligram/liter	250	1000	15.6
5	Fluoride (as F)*	Milligram/liter	1	1.5	0.00
6	Total Hardness (As CaCO3)*	Milligram/liter	200	600	110
7	Iron (As Fe)*	Milligram/liter	1	No Relaxation	0.08
8	Total Arsenic (As As)*	Milligram/liter	0.01	No Relaxation	0.00
9	E. coli*	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.00
10	Free residual Chlorine*	Milligram/liter	0.2	1	0.00
Note:					

1)*indicates parameters that are not NABL accredited.

2)This test results related to the sample tested above

3) The report shall not to be reproduced in full without approval of authority

4)This is the end of the report

Authorised signatory Khiraj Kr. Kalita



Jal Jeevan Mission Har Ghar Jal



DLL Goalpara

o/o The Executive Engineer, PHE Goalpara Div, Goalpara, Near DC office, Pin: 783121

Test report

Sample ID

U50021L80254638980

User Information

Name of the Principal:- Dr Subhash Barman

Name

Deepak Kumar Sarmah Medhi

Designation

Department

Public Health Engineering Department

Mobile

9864301782

Email

dipaksarmedh@gmail.com

Source Information

Location of the Source: - Goalpara College

Source of Sample: Treated water

Village:

GOBINDAPUR (CT)

Gram Panchayat BALADMARI

Block

BALIJANA

9.60

GOALPARA

ACCARA

District:

Goalpara College, Goalpara Town, Ward No.-6, Goalp 783101

Remarks:

4113, Goalpara College (2)

Latitude:

Longitude:

Date time of sample collection

Date time of sample received in the lab

Date & time of sample analysed

Date time of report generation

14.03.22 | 12:15 PM

14.03.22 | 01:30 PM

16.03.22 | 12:45 PM

16.03.22 | 01:05 PM

Test results

Report no

4638980

S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value Remarks
- 1	Turbidity*	NTU	1	5	0.00
2	рН*	NA	6.5-8.5	No Relaxation	7.40
3	Total Alkalinity (as Calcium Carbonate)*	Milligram/liter	200	600	40
4	Chloride (as CI)*	Milligram/liter	250	1000	12.7
5	Fluoride (as F)*	Milligram/liter	1	1.5	0.00
6	Total Hardness (As CaCO3)*	Milligram/liter	200	600	40
7	Iron (As Fe)*	Milligram/liter	1	No Relaxation	0.05
8	Total Arsenic (As As)*	Milligram/liter	0.01	No Relaxation	0.00
9	E. coli*	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.00
10 Note:	Free residual Chlorine*	Milligram/liter	0.2	1	0.00

1)*indicates parameters that are not NABL accredited.

2)This test results related to the sample tested above

3)The report shall not to be reproduced in full without approval of authority

4)This is the end of the report

Authorised signatory Khiraj Kr. Kalita



Jal Jeevan Mission Har Ghar Ial



DLL Goalpara

o/o The Executive Engineer, PHE Goalpara DIv. Goalpara, Near DC office, Pin: 783121 9613813883

Test report

U50021L802S4639002

User Information

Name of the Principal:- Dr Subhash Barman

Name

Deepak Kumar Sarmah Medhi

Designation

Department

Public Health Engineering Department

Mobile

9864301782

dipaksarmedh@gmail.com

Source Information

Location of the Source: - Goalpara College

Source of Sample:

Treated water

Village:

GOBINDAPUR (CT)

Gram Panchayat:

BALIJANA

BALADMARI

Block

District

GOALPARA

State:

ASSAM

Address

Goalpara College, Goalpara Town, Ward No.-6, Goalp 783101

Remarks:

4114, Goalpara College (3)

Latitude:

Longitude

Date time of sample collection

Date time of sample received in the lab

Date & time of sample analysed

Date time of report generation

14.03.22 | 12:20 PM

14.03.22 | 01:30 PM

16.03.22 | 12:48 PM

16.03.22 | 01:06 PM

Test results

Report no

4639002

S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value Remarks
1	Turbidity*	NTU	1	5	0.00
2	pH*	NA	6.5-8.5	No Relaxation	7.89
3	Total Alkalinity (as Calcium Carbonate)*	Milligram/liter	200	600	42
4	Chloride (as CI)*	Milligram/liter	250	1000	28
5	Fluoride (as F)*	Milligram/liter	1	1.5	0.02
6	Total Hardness (As CaCO3)*	Milligram/liter	200	600	350
7	Iron (As Fe)*	Milligram/liter	Ĩ	No Relaxation	0.04
8	Total Arsenic (As As)*	Milligram/liter	0.01	No Relaxation	0.00
9	E. coli*	CFU/100 mI	Shall not be detectable in any 100 ml sample	No Relaxation	0.00
10 Note:	Free residual Chlorine*	Milligram/liter	0.2	1	0.00

1)*indicates parameters that are not NABL accredited.

2)This test results related to the sample tested above

3)The report shall not to be reproduced in full without approval of authority

4)This is the end of the report

Authorised signatory Khiraj Kr. Kalita